NVC Control Kit

The NVC control kit is a replacement bottom circuit board for your Natural Ventilation Control.

- Model KNVC12-CONTROL is for the NVC-2-12
- Model KNVC24-CONTROL is for the NVC-2-24.



1	**Display connector:** disconnect the ribbon cable from the display when replacing the bottom board. After replacing the board and reconnecting the wires to the terminals, reconnect the ribbon cable.
2	**Connection terminals:** label the wires connected to each terminal and then disconnect them from the terminals.
3	**Screws:** remove the four screws to remove the circuit board from the enclosure.

Before installing the kit or servicing the control, switch OFF the power at the source.

Removing the old circuit board

1. Disconnect the power to the NVC.
2. Remove the cover from the unit.
3. Disconnect the ribbon cable from the bottom circuit board.
4. Label and remove the wires connected to the terminals on the bottom circuit board.
5. Remove the four screws fastening the circuit board to the enclosure.
6. Remove the circuit board from the enclosure.

Installing the new circuit board

1. Remove the new circuit board from the bag.
2. Place the new circuit board in the enclosure.
3. Fasten the circuit board to the enclosure using the four screws.
4. Connect the wires to their correct terminals.
5. Connect the ribbon cable.
6. Verify all the wires are properly connected to their correct locations.
7. Connect the power to the control and verify it operates properly. If it does not operate properly, check the wiring and ribbon cable connection. If the unit still will not operate properly, contact your dealer.
8. Fasten the cover to the enclosure using the four screws.